

# PM 2.5 Particulate Matter Data Logger

## **RN400-T2PM** User Manual



# CONTENTS

|                                       |           |
|---------------------------------------|-----------|
| <b>About this Manual</b>              | <b>04</b> |
| Intellectual Property Rights .....    | 04        |
| Notational Conventions .....          | 04        |
| <b>Introduction</b>                   | <b>05</b> |
| Key Features .....                    | 06        |
| Exterior .....                        | 06        |
| Accessories .....                     | 07        |
| Specifications .....                  | 07        |
| <b>Installation</b>                   | <b>08</b> |
| Terminal Block .....                  | 09        |
| Data Logger Installation .....        | 10        |
| Connecting Terminal Block .....       | 12        |
| <b>Operation</b>                      | <b>14</b> |
| Viewing Channel Information .....     | 15        |
| Viewing Device Information .....      | 16        |
| Resetting Data Logger .....           | 17        |
| Memory Card for Data Logging .....    | 18        |
| <b>Configuration</b>                  | <b>19</b> |
| Device Information .....              | 21        |
| Server .....                          | 22        |
| Measurement .....                     | 23        |
| Wi-Fi Network .....                   | 24        |
| Display .....                         | 27        |
| Commands .....                        | 28        |
| Memory Card Usage Configuration ..... | 29        |

|   |           |
|---|-----------|
| Checking Communication With Radionode365 Server ..... | 30        |
| RS-485 Modbus Communication .....                     | 30        |
| <b>Radionode365</b> .....                             | <b>31</b> |
| Adding Devices from Your Smartphone .....             | 32        |
| Adding Devices from Your Computer .....               | 35        |
| <b>Maintenance</b> .....                              | <b>38</b> |
| Cleaning .....  | 38        |
| Batteries .....                                       | 38        |
| Firmware Update .....                                 | 39        |
| <b>Customer Service Information</b> .....             | <b>40</b> |
| Manufacturer Contact Information .....                | 40        |
| Warranty .....  | 40        |
| Limit of Liability .....                              | 40        |
| Certifications .....                                  | 41        |
| <b>HTTP Radionode Protocol V2</b> .....               | <b>42</b> |
| Check-in .....  | 42        |
| Data-in .....   | 45        |
| <b>Order List</b> .....                               | <b>46</b> |
| Data Logger .....                                     | 46        |
| Accessories .....                                     | 46        |

# About this Manual

This document contains instructions for usage and installation of the RADIONODE® RN400-T2PM. Product specifications and certain features herein may be subject to change without prior notice. Figures used in this manual are for explanatory purposes only, and may differ from your system depending on installation conditions. Software screenshots may change after software updates.

## Intellectual Property Rights

© 2021 DEKIST Co., Ltd.

All contents and figures herein are property of DEKIST Co., Ltd. Reproduction or redistribution of all or part of this document in any way is not permitted without prior consent from DEKIST.

## Notational Conventions



Failure to follow instructions marked with "Warning" may result in slight injury to the user.



Failure to follow instructions marked with "Caution" may result in equipment damage or malfunction.



Additional helpful information is marked with "Note".

# Introduction

The RN400-T2PM Data Logger periodically measures the concentration of PM 2.5 particulate matter (also known as fine dust) in the atmosphere by size and sends measurement data to the Radionode365 server. RN400-T2PM comes with a total of six I/O channels.

|           | Accumulative Range  | Segment Range  |
|-----------|---|--|
| Channel 1 | $0.3 \mu\text{m} \leq \text{PM}_{2.5} \leq 2.5 \mu\text{m}$ | $1.0 \mu\text{m} < \text{PM}_{2.5} \leq 2.5 \mu\text{m}$ |
| Channel 2 | $0.3 \mu\text{m} \leq \text{PM}_{10} \leq 10 \mu\text{m}$   | $4.0 \mu\text{m} < \text{PM}_{10} \leq 10 \mu\text{m}$   |
| Channel 3 | $0.3 \mu\text{m} \leq \text{PM}_{0.5} \leq 0.5 \mu\text{m}$ | $0.3 \mu\text{m} < \text{PM}_{0.5} \leq 0.5 \mu\text{m}$ |
| Channel 4 | $0.3 \mu\text{m} \leq \text{PM}_{1.0} \leq 1.0 \mu\text{m}$ | $0.5 \mu\text{m} < \text{PM}_{1.0} \leq 1.0 \mu\text{m}$ |
| Channel 5 | $0.3 \mu\text{m} \leq \text{PM}_{4.0} \leq 4.0 \mu\text{m}$ | $2.5 \mu\text{m} < \text{PM}_{4.0} \leq 4.0 \mu\text{m}$ |
| Channel 6 | Number of particles largest in size                         |  |

The unit of measurement is  $\mu\text{g}/\text{m}^3$ . If Channel 1 measurement is 42.75, then particles 0.3 – 2.5  $\mu\text{m}$  in size in the space of 1 meter<sup>3</sup> weigh 42.75 micrograms.

The PM size is a cumulative range. As a size of  $\text{PM}_{10}$  includes that of  $\text{PM}_{2.5}$ , the measurement of Channel 2 is always equal to or greater than the measurement of Channel 1. Use the UA Calibrator program to switch the PM size from accumulative range to segment range. For more information on the UA Calibrator, see [RS-485 Modbus Communication](#) on page 30.

If Channel 6 measurement is 127, then the number of particles biggest in size among other particles in the space of 1 meter<sup>3</sup> is 127.

Only measurements of Channels 1, 2 and 6 are displayed as data in the Data Logger. Use Radionode365 to see measurements of all channels.


## Key Features

Key features of the RN400-T2PM include:



- Use Wi-Fi connection to easily configure your Data Logger.
- Measurement data can be viewed remotely from Radionode365 website. See [Radionode365](#) on page 31.
- Measurement data can be logged on a micro SD card.
- Modbus RTU (RS-485) communication allows PLC to access Data Logger.

## Exterior




- |                |               |                  |
|----------------|---------------|------------------|
| 1 Display      | 2 Menu button | 3 Display button |
| 4 Power button | 5 Cable gland |                  |

Power cables and PLC or other device cables are connected via cable glands to the internal terminal block.


For instructions on how to use the buttons, see [Operation](#) on page 14.

# Accessories

All accessories, including batteries, are sold separately.




3.6 V Battery



DC Adapter (12 V, 500 mA)

In the event of power failure, a C-type 3.6 V battery must be placed in the Data Logger. RADIONODE Data Logger is designed to not operate without a battery, even when external power is connected.

# Specifications



|                         |  |
|-------------------------|--|
| Wi-Fi                   | 2.4 GHz IEEE 802.11 b/g/n, WPA2-Enterprise |
| RS485                   | Modbus RTU                                 |
| Cable Gland             | PG-9                                       |
| Water Resistance Rating | IP65                                       |
| External DC Power       | 5 ~ 30 V (Built in UPS)                    |
| Size                    | 165 × 50 × 115mm                           |
| Operating Conditions    | -10 ~ 60 °C, 0 ~ 95% RH (non-condensed)    |

# Installation

The following procedure will guide from the installation procedure to the Radionode365 registration process.


- 1.** Install sensors or connect other devices to the Data Logger as needed.
- 2.** Connect power and insert the battery.
- 3.** Use the virtual Wi-Fi router feature to configure the Data Logger. See [Configuration](#) on page 19.
- 4.** Now that the Data Logger has been installed, it must be registered to Radionode365. See [Radionode365](#) on page 31.

Depending on your installation circumstances and conditions, your installation process may vary. For example, if you are installing multiple Data Loggers, you might find it easier to:

- 1.** Insert batteries into all Data Loggers before running.
- 2.** Configure one Data Logger first.
- 3.** Use a micro SD card to set up additional Data Loggers. For this method, see [Memory Card Usage Configuration](#) on page 29.
- 4.** Register the Data Loggers onto Radionode365.
- 5.** Finally, install the Data Loggers.

# Terminal Block

Terminal Blocks can be found inside of a Data Logger, with other components arranged as follows:



- |                      |                  |                         |
|----------------------|------------------|-------------------------|
| 1 Micro SD Card Slot | 2 Micro USB Port | 3 Battery Holder        |
| 4 Fine Dust Sensor   | 5 Temp Sensor    | 6 Power Outlet Terminal |

Micro SD card is used to log measurement data. see [Memory Card for Data Logging](#) on page 18.


The micro USB port is used for sensor calibration. As RN400 Series sensors are shipped after calibration, no further calibration is required. However, if the sensor malfunctions, contact DEKIST for inspection.

For more information on the terminal block, see [Connecting Terminal Block](#) on page 12.


# Data Logger Installation

The general procedure for installing a Data Logger is as follows:


1. Loosen the screw on the right side of the front panel and open the front panel.




2. Loosen the cable gland.




3. Route the cables of the device that will be connected through the gland and connect to the terminal block. Then, connect external DC power and insert the battery. For more information on terminal block connection, see [Connecting Terminal Block](#) on page 12.




4. Tighten the gland firmly.




5. Cover the front panel and tighten the screws.




6. The Data Logger is equipped with a magnet at the rear. Place the Data Logger on a steel panel.



If necessary, use screws to secure. There are three screw holes on the back of the device.



# Connecting Terminal Block




When connecting cables to the terminal block, ensure that the flat cable does not get disconnected from the front connector.

## RS485

Connect the RS485 cable to the **RS485** terminal. Connect the cable linked to the **A** terminal of the other device to the **A** terminal, and the remaining cables to the **B** terminal.


For more information on how to change Modbus communication settings, see [RS-485 Modbus Communication](#) on page 30.



If no external DC power is supplied, the RS485 terminal will not function.


## DC Power

Connect the Power cable to the **POWER** terminal. Connect the red cable to the **+** terminal, and the remaining cables to the **-** terminal.



# Batteries


Insert a C-type 3.6 V battery into the battery holder



Be careful not to connect batteries with opposite polarities. Doing so may damage the device.

# Operation

When the data logger is turned on, the model number and other key information is displayed with the corresponding measurements. If no external power is supplied, the display will turn off shortly and the Data Logger will enter sleep mode.



- **Viewing Channel Information:** To view channel information, including measurements on sleep mode, press the **W** button. Press the **W** button repeatedly to display different status information.
- **Selecting a Menu:** Press the **W** button, then press the **S** button. Press the **S** button repeatedly to display different menu items. Press the **W** button to open the displayed menu. Press the **P** button to exit the menu.
- **Turning Data Logger Off:** Press the **W** button and hold the **P** button until `PRESS 'P' ONE MORE TO POWER IT OFF` appears. Hold the **P** button again.
- **Turning Data Logger On:** Press the **P** button.

# Viewing Channel Information

Press the **W** button repeatedly to display the below channel data. A sensor channel that is not connected will appear as (none).

```
LAST SENSING IS:menu  
PM2.5 18.87 ug/m3
```

Measurement of Channel 1 (concentration of PM<sub>2.5</sub> particle)

```
LAST SENSING IS:menu  
PM10 20.01 ug/m3
```

Measurement of Channel 2 (concentration of PM<sub>10</sub> particles)

```
LAST SENSING IS:menu  
PM0.5 127.36 #/m3
```

Measurement of Channel 6 (number of particles largest in size)

```
LAST TRANSMIT IS:menu  
5 Min Ago, 9 smpl
```

Elapsed time since last transfer of measurement data to the server & number of datasets to transfer in the next cycle

```
WIFI SSID dB IS:menu  
xxxxxxxx, -50dB
```

Wi-Fi network name and signal strength

```
LOCAL TIME IS:menu  
2020-11-30 17:00
```

Current date and time

```
BATTERY STAT. IS:menu  
OK. 11.5Vx2 12.88V
```

Type of battery inserted and current voltage. If the voltage is low, LOW will be displayed.

```
DATA FILTER. IS:menu  
SLOW LEVEL (1-15):1
```

You can select the level of the digital filter. The higher the number, the less sensitive the sensor reacts (1 level: highest sensitive, 15 level: lowest sensitive). You can choose from the settings menu.

```
GS CELL TEMP. IS:menu  
CELL Temp: 22 C
```

**[ONLY RN400-T2GS]** Displays the temperature value of the chemical cell inside the product.

# Viewing Device Information

To view device information, select 1.VIEW INFO. To view the next item, press the **S** button. To exit, press the **P** button.

```
INFO!S:next, P:exit  
1.HOLDING DATA: 4
```

Number of datasets to send to the server in the next cycle.

(number of datasets to send = Transfer Interval ÷ Measurement Interval)

When measurement interval is set to 5 minutes and the transfer interval set to 20 minutes, 4 datasets are saved until the next transfer. If data transfer fails, datasets accumulate until successful.

```
INFO!S:next, P:exit  
2.POWER: External DC
```

If no external power is connected or power failure occurs, Bat will appear.

```
INFO!S:next, P:exit  
3.SENSING: 1 Min
```

Measurement interval

```
INFO!S:next, P:exit  
4.SENDING: 5 Min
```

Measurement data transmission to server interval

```
INFO!S:next, P:exit  
5.UPDATE: 1 Min Ago
```

Time elapsed since last transmission of measurement data to server

```
INFO!S:next, P:exit  
6.ID: xxxxxxxx
```

Radionode365 account ID

```
INFO!S:next, P:exit  
7.IP:192.168.10.13
```

Data Logger IP Address

```
INFO!S:next, P:exit  
8.GW:192.168.1.1
```

Gateway IP address

```
INFO!S:next, P:exit
9.DN:210.220.163.82
```

DNS server IP address

```
INFO!S:next, P:exit
10.MAC:508CB16FA1B3
```

Data Logger MAC address

```
INFO!S:next, P:exit
11.SW BUILD:20200720
```

Firmware version

```
INFO!S:next, P:exit
12.MODEL:RN400T2PM
```

Model No.

```
INFO!S:next, P:exit
13.CAL:2020-12-25
```

Date of sensor calibration

```
INFO!S:next, P:exit
14.MODE: ug/m3,CUM
```

Measurement unit and type of PM range.

CUM is the cumulative range.

## Resetting Data Logger

All setting options (except for Wi-Fi network) can be reset. Select 4.FACTORY DEFAULT.


# Memory Card for Data Logging

If a memory card is installed in the Data Logger, measurement data will be written to the memory card as a CSV file as follows:

Measurement date, timestamp, MAC address, value for Channel 1, ... , value for Channel 6

|   | A                    | B          | C            | D     | E     | F      | G     | H     | I    |
|---|----------------------|------------|--------------|-------|-------|--------|-------|-------|------|
| 1 | CALENDAR(GMT 9)      | TIMESTAMP  | MACADDR      | CH1   | CH2   | CH3    | CH4   | CH5   | CH6  |
| 2 | 2020-12-01T08:38:40Z | 1606779520 | E415F64F5466 | 13.35 | 13.71 | 83.06  | 12.29 | 13.65 | 0.58 |
| 3 | 2020-12-01T08:49:44Z | 1606780184 | E415F64F5466 | 11.38 | 11.44 | 73.01  | 10.71 | 11.43 | 0.57 |
| 4 | 2020-12-01T08:59:44Z | 1606780784 | E415F64F5466 | 12.56 | 12.62 | 80.48  | 11.81 | 12.61 | 0.57 |
| 5 | 2020-12-01T09:09:44Z | 1606781384 | E415F64F5466 | 16.96 | 16.99 | 109.2  | 16.01 | 16.99 | 0.55 |
| 6 | 2020-12-01T09:19:44Z | 1606781984 | E415F64F5466 | 17.01 | 17.2  | 108.06 | 15.89 | 17.17 | 0.57 |

Open the front of the Data Logger and insert a micro SD card into the card slot inside the front panel.



Use an SD card (up to 16 GB) formatted with the FAT32 file system. Other file systems are not supported.


# Configuration

The Data Logger is equipped with a virtual Wi-Fi router. The virtual router allows your smartphone or tablet to be linked to Data Logger for configuration.


1. Select **2.CONFIG MODE (AP)** to enable the virtual router. The following will appear in the display:

```
SOFTAP:  _RN400-A1B3  
ACCESS: 192.168.1.1
```

2. On your smartphone, find the Wi-Fi network with the same name as shown on the display and connect to the network.




Depending on the version of your Android phone, user identification may be required, as Data Logger is not connected to the Internet.



Multiple mobile devices cannot be connected to the Data Logger at the same time.

3. Open your smartphone's web browser and type "192.168.1.1" in the address bar. The Settings page will appear.



4. Change the settings on each page, then tap **Save**.
5. To finish configuration, tap **Reboot**.

# Device Information

Tap **SYSTEM** to view Data Logger device information.



|                     |   |
|---------------------|---|
| Radionode365 Owner  | Radionode365 account ID   |
| MAC address         | Data Logger MAC address   |
| Model Name          | Data Logger model number  |
| Firmware version    | Firmware version  |
| OTA Release Version | OTA release version   |
| SDCARD Inserted     | If a memory card is not inserted, <b>No SDCard</b> will appear. |
| WIFI SSID           | The Wi-Fi network used by the Data Logger                       |
| IP address          | Data Logger IP Address  |
| Gateway Address     | The gateway IP address to which the Data Logger is connected    |
| DNS                 | DNS server IP address   |

Tap **SERVER SETUP** to configure server receipt of measurement data.

|                     |   |
|---------------------|---|
| <b>Destination</b>  | <ul style="list-style-type: none"> <li>▪ Select <b>Radionode365</b> to send measurement data to the Radionode365 server.</li> <li>▪ Select <b>User HTTP Server</b> to send to a customer or third-party server, and configure the below items accordingly.</li> <li>▪ Select <b>SDCard Logger</b> to operate Data Logger independently without a server.</li> </ul> |
| <b>Host</b>         | Server IP address   |
| <b>Port</b>         | Server port number  |
| <b>Check-in URL</b> | URL of the server program that processes check-in requests  |
| <b>Data-in URL</b>  | URL of the server program that processes data-in requests.  |

 For check-in and data-in request formats, see [HTTP Radionode Protocol V2](#) on page 42.

This item will appear if **Destination** is set to **SDCard Logger**.

|                            |   |
|----------------------------|---|
| <b>SD Card Data Logger</b> | If set to "0," measurement data will begin to be written to the memory card as soon as booting completes. If set to "10", data will be written 10 minutes after booting completes. For more information, see <a href="#">Memory Card for Data Logging</a> on page 18. |
|----------------------------|---|

# Measurement

Tap **MEASUREMENT** to configure sensor operation.

|                                   |   |
|-----------------------------------|---|
| <b>Sensing - Sending Interval</b> | Select the interval between sensor measurement and data transmission. For instance, if <b>Sensing 1Min - Sending 5Min</b> is selected, sensor measures every 1 minute, and measurement data is sent to the server every 5 minutes, or written on a memory card. |
| <b>Temperature Scale</b>          | Ignore this item.   |
| <b>Temp</b>                       | Ignore this item.   |
| <b>RH</b>                         | Ignore this item.   |
| <b>AVG Filter</b>                 | Adjusts the sensor sensitivity. The margin of error ranges from 1 to 15, and the higher the value, the lower the sensitivity.   |
| <b>CH info</b>                    | Displays a list of output channels.   |

On the **SERVER SETUP** page, set the **Destination** to **User HTTP Server** to add seconds to the list of selectable options.

# Wi-Fi Network

Tap **WIFI/NETWORK SETUP** to configure the Wi-Fi network that will be used by the Data Logger.

|                                  |  |
|----------------------------------|--|
| <b>Access Point</b>              | Select a network to use from the list of searched Wi-Fi networks. The closer the signal strength is to 0 dBm, the stronger the connection. If possible, use a Wi-Fi network with a signal strength of -70 dBm or higher. |
| <b>SSID</b>                      | The selected SSD will appear.  |
| <b>Security Type</b>             | Select the type of security that your Wi-Fi network uses.  |
| <b>Personal Security Type</b>    | If <b>Security Type</b> is set to <b>Personal</b> , select the current security type.  |
| <b>Security KEY/PIN</b>          | Enter your Wi-Fi password.   |
| <b>DHCP/Static (Auto/Manual)</b> | If <b>DHCP</b> is selected, the router will randomly assign an IP Address. If a static IP address is needed, select <b>Static</b> and configure additional settings.   |

If a static IP address is needed, select **Static** and configure additional settings as follows:

DHCP/Static (Auto/Manual)

DHCP  Static

IP

Gateway

Subnet

DNS

|                |                        |
|----------------|------------------------|
| <b>IP</b>      | Data Logger IP Address |
| <b>Gateway</b> | Gateway IP address     |
| <b>Subnet</b>  | Subnet mask            |
| <b>DNS</b>     | DNS server IP address  |

# Enterprise Security (WPA Enterprise)

When connecting to a Wi-Fi network that uses enterprise security, the certificate is passed from Data Logger to the RADIUS server along with the RADIUS server account. Once user's access is authorized by the RADIUS server, access to the network is granted.


To connect to a network that uses enterprise security, adhere to the following procedure:

1. Copy the RADIUS server certificate to a micro SD card with the following path and filename:

```
/cert/ca.pem
```

 Ask your network administrator for a certificate in a PEM format. Certificates in other formats are not supported.

2. On the WIFI/NETWORK SETUP page, set the Security Type option to Enterprise and configure the following additional settings:



|                        |                          |
|------------------------|--------------------------|
| Personal Security Type | Security type            |
| RADIUS UserID          | RADIUS server account ID |
| RADIUS Password        | RADIUS ID password       |

# Display

Tap DISPLAY/OTHERS to configure display and other options.

|                          |  |
|--------------------------|--|
| Display Timer OP Mode    | This setting can be configured with other settings to set the display operation interval during sleep mode. Select how long the display will stay on in minutes. Select <b>Always</b> to disable sleep mode. |
| Display Timer Start Time | Select what time the display will turn on.   |
| Timezone                 | Select which timezone to use.  |
| Copy Now                 | See <a href="#">Memory Card Usage Configuration</a> on page 29.  |
| Debug Code               | Enter a command to perform a specific function. See the following section for a detailed explanation.  |

# Commands

On the **DISPLAY/OTHERS** page, the following commands can be entered in **Debug Code**. Enter a command in uppercase, then tap **Execute**.


|                                |   |
|--------------------------------|---|
| <b>ATVMAC<br/>xxxx0000xxxx</b> | Enter the address that will be used as the virtual MAC address. |
| <b>ATCLF</b>                   | The virtual MAC address is replaced by the original address.    |
| <b>ATNODNS 1</b>               | DNS settings are ignored.                                       |
| <b>ATNODNS 0</b>               | DNS settings become valid again.                                |
| <b>ATLOG 1</b>                 | Event logs are saved on the memory card.                        |
| <b>ATLOG 0</b>                 | No event logs are created.                                      |
| <b>ATNOWIF 1</b>               | The Wi-Fi feature is enabled.                                   |
| <b>ATOWIF 0</b>                | The Wi-Fi feature is disabled.                                  |

# Memory Card Usage Configuration

Memory cards facilitate the configuration of multiple Data Loggers at once.

1. Back up the setup data on a memory card in the configured Data Logger.

- a) Insert a micro SD card into the Data Logger.




- b) On the DISPLAY/OTHERS page, tap **Copy to SD Card > Copy Now**.



- c) Remove the SD card.

2. Copy the setup data from the SD card to another Data Logger.

- a) Insert the SD card into the Data Logger.
- b) Use the **P** button to turn the Data Logger off.
- c) Press both the **S** and **W** buttons simultaneously and hold the **P** button to turn the Data Logger on.



If **NEW CONFIG FILE IS LOADED** appears, the setup data has been copied successfully.



Use an SD card (up to 16 GB) formatted with the FAT32 file system. Other file systems are not supported.


# Checking Communication With Radionode365 Server

From the Data Logger, select **6. CHECK SYSTEM** to ensure that data are successfully updated when adding I/O channels in Radionode. Measurements are displayed every 3 seconds and sent to the Radionode365 server. On the web page, verify that the displayed values match the ones shown. Press the **P** button to finish.

## RS-485 Modbus Communication

The UA Calibrator program is required to change settings of Modbus RTU communication. Download and install UA Calibrator from the Radionode web site at [www.radionode365.com](http://www.radionode365.com).


1. From the Data Logger, select **3. USB CALIBRATION**.
2. Connect the Data Logger to your computer using a USB cable.
3. Run UA Calibrator on your computer. When the Data Logger is successfully recognized, the following will appear on the monitor:



4. Change Modbus settings accordingly.
5. Press the **P** button to finish.

# Radionode 365

Radionode365 is a cloud-based sensor monitoring web application operated by DEKIST, a radionode manufacturer. We offer data storage for all sensor-measured data, and provide various features such as emergency alarms, reports, and real-time status based on stored data.



This chapter outlines how to add new devices and channels to Radionode365. For more information on Radionode365, see the information provided on the web page below:

<https://help.radionode365.com/article-categories/tp365-manual>

Key features of Radionode365 include:


- Measurement data displayed in real-time;
- View measurement data records via charts;
- Create and email periodic reports;
- Alarms notifications sent via e-mail, text, or voice message in the event of an alarm.

Create a user account at the address below to access Radionode365.

<https://s2.Radionode365.com/html/memberjoin.html>


# Adding Devices from Your Smartphone

At the **New Device** page, you will find a unique QR code for your account. The QR code allows you to easily add devices and channels to your smartphone.



Scan the QR code with your smartphone. Alternatively, copy the link address from the QR code image and send it to your smartphone.


1. Your smartphone's default web browser will open with your user information. Tap **Add Device**.




When the RN400 Series Data Logger first connects to Radionode365, its identification code (i-code) is displayed as follows:

```
Enter iCode on TP365
iCode: 2024
```

2. Enter the i-code on the device display. If you do not see an i-code on the display, tap **Search by MAC address** and enter your MAC address.



3. If the i-code or MAC address is correct, the device information will appear as below. Tap **Next**.



4. Enter your device name, check the box of the channel that will be used, then enter the channel name and unit that will be used. Tap **Next** to finish.

Tapaculo365

## Device Registration



**RN400T2GS**

Please Enter **Device** name

Please Enter **Channel** name

Channel1 Name ppm ✓

Channel2 Name ppm ✓


**Next**

Home

# Adding Devices from Your Computer

## Adding Devices

The **New Device** page will appear if there is no added device on login. To add a device that was added later, click **Device Setup > New Device**.




| ID/MAC       | Device Model | Public IP      | Private IP   | RF Power | RF Channel | Network ID | Firmware   | Sending Interval | Sampling Interval | Last Update | Last Update time    | Add Device |
|--------------|--------------|----------------|--------------|----------|------------|------------|------------|------------------|-------------------|-------------|---------------------|------------|
| E415F54F43FA | RN4007ZGS    | 61.101.112.152 | 192.168.0.10 | -        | -          | -          | 20200616   | 120 sec          | 120 sec           | 5 mins ago  | 2021-01-19 11:05:34 | Add Device |
| 049162E32CF3 | RN171        | 61.101.112.152 | 192.168.0.42 | -        | -          | -          | Sep 4 2020 | 120 sec          | 120 sec           | 5 mins ago  | 2021-01-19 11:05:34 | Add Device |
| E415F54F5466 | RN4007ZPM    | 61.101.112.152 | 192.168.0.45 | -        | -          | -          | 20200730   | 120 sec          | 120 sec           | 5 mins ago  | 2021-01-19 11:05:34 | Add Device |
| 508216F4183  | RN4007DEX    | 61.101.112.152 | 192.168.0.40 | -        | -          | -          | 20200720   | 120 sec          | 120 sec           | 5 mins ago  | 2021-01-19 11:05:34 | Add Device |
| D4B394C3987  | RN4007DEX    | 61.101.112.152 | 192.168.0.39 | -        | -          | -          | 20200720   | 120 sec          | 120 sec           | 5 mins ago  | 2021-01-19 11:05:34 | Add Device |

Devices found in the same IP band are listed here. If you do not see your device in the list, you can add it using its i-code. When RN400 Series first connects to Radionode365, its i-code is displayed as follows:

```
Enter iCode on TP365
iCode: 2024
```

Enter the i-code above the device list and click **Search**. Devices can also be searched via MAC address instead of their i-code. The device will be then be added to the list.

To add your device, click the **Add Device** button in the last column.



Add Device

After registering new device, new data channel will come up on new data channel menu within interval time.

No Image

Device Name:

Device Comment:

Enter your device name in the window that appears, upload a picture of the installed device, then click **Save**.

# Adding Channels

Once your device has been added, click **Device Setup > New Data Channel**. All added device channels will be listed.

| ID/MAC                            | Device Name | Device Model | Last Value | RF Signal | Battery    | Sending Interval | Sampling Interval | Last Update | Last Update time    | Add Channel |
|-----------------------------------|-------------|--------------|------------|-----------|------------|------------------|-------------------|-------------|---------------------|-------------|
| E415F64F3FA-0000E415F64F3FA-ch1   | RN400-T2GS  | RN400T2GS    | 0.88       | Excellent | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3FA-0000E415F64F3FA-ch2   | RN400-T2GS  | RN400T2GS    | NULL       | Excellent | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch1 | RN400-T2PM  | RN400T2PM    | 1          | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch2 | RN400-T2PM  | RN400T2PM    | 39.28      | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch3 | RN400-T2PM  | RN400T2PM    | 246.79     | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch4 | RN400-T2PM  | RN400T2PM    | 36.50      | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch5 | RN400-T2PM  | RN400T2PM    | 39.21      | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |
| E415F64F3466-0000E415F64F3466-ch6 | RN400-T2PM  | RN400T2PM    | 0.59       | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | 2021-01-19 11:55:34 | Add Channel |

This list also includes channels not associated with external sensors or other devices. Adding a channel essentially means selecting a channel to monitor. To add a channel, click the **Add Channel** button in the last column.

Channel ID: E415F64F3FA-0000E415F64F3FA-CH2      Channel Model: RN400T2GS

\* Channel Name:

\* Unit:      

Channel Comment:


Enter the channel name in the window, select/enter a unit to use, then click **Save**.

To view the list of added channels, click **Device Setup > Channel List**.

| Channel Name    | Device Name | Device Model | Last Value | UNIT  | RF Signal | Battery    | Sending Interval | Sampling Interval | Last Update | Modify/Delete |
|-----------------|-------------|--------------|------------|-------|-----------|------------|------------------|-------------------|-------------|---------------|
| NH3             | RN400-T2GS  | RN400T2GS    | 0.77       | ppm   | Excellent | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-H2EX-CH1  | RN400-H2EX  | RN400H2EX    | 77.51      | °C    | Good      | Full/Full  | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-H2EX-CH2  | RN400-H2EX  | RN400H2EX    | 19.86      | %     | Good      | Excellent  | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-H2EX-CH3  | RN400-H2EX  | RN400H2EX    | 20.80      | °C    | Good      | Excellent  | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-H2EX-CH5  | RN400-H2EX  | RN400H2EX    | 0.00       | int.  | Good      | Excellent  | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-H2EX-CH6  | RN400-H2EX  | RN400H2EX    | 0.00       | int.  | Good      | Excellent  | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-T2EX-CH1  | RN400-T2EX  | RN400T2EX    | 22.30      | °C    | Good      | Bad        | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-T2EX-CH14 | RN400-T2EX  | RN400T2EX    | 0.00       | int.  | Good      | Bad        | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-T2PM-CH1  | RN400-T2PM  | RN400T2PM    | 38.84      | ug/m3 | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |
| RN400-T2PM-CH2  | RN400-T2PM  | RN400T2PM    | 39.28      | ug/m3 | Good      | D.C. Power | 1000 sec         | 1000 sec          | 5mins ago   | Modify        |

# Adding Widgets

A widget contains one or several channels. You can add a widget to the dashboard by clicking **Dashboard**, then **Add widget**.



Enter the widget name in the window, select channels, then click **Save**.

# Maintenance

## Cleaning

Use a dry cloth to clean the Data Logger. Do not use solvents or abrasives. Not only do these substances damage the surface of the Data Logger, but they may also affect sensor performance.

## Batteries

Replace the battery when the battery status on the Radionode365 web page is **Bad**, or if it appears as follows:

```
WARNING! !S:menu  
Low Battery!
```

 When the measurement interval and transfer interval are set to the lowest frequency, the battery is expected to last up to 1 year without external power.


# Firmware Update

The Data Logger can be updated with new firmware to correct errors or enhance features. Latest firmware is distributed optionally depending on your circumstances.

1. Copy the firmware file to a micro SD card to the following path and insert it into Data Logger. The file name is the same as the model number.

```
/img/t2pm.bin
```

2. Insert a micro SD card into the Data Logger.
3. Use the **P** button to turn the Data Logger off.
4. Press both the **S** and **W** buttons simultaneously and hold the **P** button to turn the Data Logger on.



If **NEW IMAGE FILE IS LOADED** appears, the firmware will be updated successfully.



Use an SD card (up to 16 GB) formatted with the FAT32 file system. Other file systems are not supported.

# Customer Service Information

## Manufacturer Contact Information

DEKIST Co., Ltd. provides repair service and replacement parts for RADIONODE products. To request customer service, contact us via one of the following methods.

- Tel: +(82) 1566-4359
- Fax: +(82) 31-8039-4400
- E-mail: master@dekist.com

## Warranty

Repairs are provided free of charge for product failure under normal operating conditions within one year of the product installation date.

## Limit of Liability

Warranty repairs are not provided in the event of:

- Failure caused by unapproved installation methods;
- Failure caused by user negligence;
- Failure caused after alteration, disassembly, or repair of the product by a person unauthorized by DEKIST;
- Failure caused by corrosion, falling, submersion, or other improper storage methods;
- Failure caused by natural disaster or other unforeseen circumstances, such as storms, floods, earthquakes, lightning, or abnormal voltage;
- Service requested for actions that the user can take, such as replacing consumables;
- Alteration of the software through decompilation or the like

# Certifications

## FCC Class A Digital Device

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.



Changes or modifications not expressly approved by the manufacturer responsible for compliance could void the user's authority to operate the equipment.

---

## KC

This equipment has passed conformity testing for use in work environments, and is likely to cause interference when used in a household environment.

# HTTP Radionode Protocol V2

Radionode users can build their own servers that receive measurement data from radionode devices, such as the RN400 Series data loggers or RN17x Series data transmitters, instead of the Radionode365. This chapter describes the POST-method HTTP request format used by radionode devices for customer server developers.

Customer servers must process the following two requests:

- The radionode device requests transmission of device information from the server at the start of operation and every six hours thereafter. This request is called check-in.
- The device requests transmission of measurement data from the server at the set time. This request is called data-in.

## Check-in

Check-in requests are in the following format:

```
POST / HTTP/1.1
Host: 192.168.10.1/checkin
Content-Type: application/x-www-form-urlencoded
Content-Length: 589

mac=0000xxxx0000&
ver=20201031&
model=RN171&
ip=192.168.100.11&
splrate=60&
interval=300&
tags=xxx|xxx|xxx
```

In `192.168.10.1/checkin`, `checkin` is the server program name that processes check-in requests, which can be either `checkin.php`, `checkin.asp` or `checkin.js`.

- `mac`: MAC address of the device
- `ver`: Firmware version
- `model`: Model No.
- `ip`: IP address
- `splrate`: Measurement interval
- `interval`: Data transfer interval
- `tags`: CH info

This parameter is separated by vertical lines (|) and indicates the nature of each channel.

```
tags=TEMP|RH|NTC_TEMP|NULL|NULL|NULL
```

In this example, there are a total of six channels with Channel 1 indicating temperature, Channel 2 indicating RH, and Channel 3 indicating the temperature measured by NTC external temperature sensor. The remaining channels are not associated sensors or devices.

The server must reply to a check-in request in the following XML format:

```
<xml>
<root>
<ack>ok</ack>
<timestamp>1501912142</timestamp>
<offset-ch1>0.6</offset-ch1>
<offset-ch2>1.3</offset-ch2>
<sample-mode>3</sample-mode>
</root>
</xml>
```

The first two of the five tags are mandatory, whereas the remaining three tags are options, subject to change according to the server's reply.

- **ack**: Processing outcome (**ok** or **error**)
- **timestamp**: Current time of the server in UNIX timestamp format
- **offset-ch1**: Calibration Value of Channel 1
- **offset-ch2**: Calibration Value of Channel 2
- **sample-mode**: Measurement and Transfer Intervals.

If this tag's value is "3," the measurement interval changes to 5 minutes and the transfer interval to 20 minutes. See the following table:

|                      | 1    | 2   | 3    | 4    | 5    | 6    | 7    | 8    | 9    | 10   | 11   | 12   | 13   |
|----------------------|------|-----|------|------|------|------|------|------|------|------|------|------|------|
| Measurement interval | 1 m  | 1 m | 5 m  | 5 m  | 10 m | 10 m | 10 m | 10 m | 20 m | 30 m | 10 s | 10 s | 10 s |
| Transfer Interval    | 10 m | 5 m | 20 m | 10 m | 10 m | 30 m | 20 m | 60 m | 40 m | 60 m | 10 s | 30 s | 60 s |



**sample-mode** Note that when setting a tag to a value greater than 10, setting measurement and transfer intervals in seconds may cause rapid battery depletion.

# Data-in

Data-in requests are in the following format:

```
POST / HTTP/1.1
Host: 192.168.10.1/datain
Content-Type: application/x-www-form-urlencoded
Content-Length: 589
```

```
mac=0000xxxx0000&
sig=40&
bat=255&
volt=1|3.12&
SMODEL=RN400H2EX&
C000=1505912142|23.22|12.44|122.11|123&
P000=1505911542|23.19|12.40|121.96|123&
P001=1505910942|23.18|12.52|122.04|123&
```

- **mac**: MAC address of the device
- **sig**: Strength of wireless signal
- **bat**: Battery status.

The value ranges from 0 to 255. The battery must be replaced when the value is "5" or less. "-1" is displayed when DC power is connected.

- **volt**: Battery type and current voltage.  
"0" indicates two 1.5 V batteries are inserted and "1", one 3.6 V.
- **SMODEL**: Model number of the device
- **Cxxx**: Current measurement of each channel.

This parameter is separated by vertical lines (|) and indicates the values of the timestamp and each channel.

```
C000=Timestamp|Ch. 1|Ch. 2|Ch. 3|Ch. 4
```

- **Pxxx**: Past channel measurements

The server must reply to a data-in request with a process outcome in the following format:

```
<xml>
<root>
<ack>ok</ack>
</root>
</xml>
```

# Order List

## Data Logger

| Type                           | Model No.  | Compatible External Sensors   |
|--------------------------------|------------|---|
| Temp, RH                       | RN400-H2PS | PR-P1-3, PR-P1-15, PR-K1-3, PR-K1-15                                    |
| Temp, RH,<br>Door              | RN400-H2EX | PR-P1-3, PR-P1-15, PR-K1-3, PR-K1-15<br>AP-D1, AP-W1                    |
| Temp                           | RN400-T2PS | PR-N1-20, PR-N1-150, RG20   |
| Temp,<br>Door                  | RN400-T2EX | PR-P1-3, PR-P1-15, PR-K1-3, PR-K1-15<br>PR-T1-3, PR-T1-15, AP-D1, AP-W1 |
| Temp                           | RN400-T2TS | PR-K1-3, PR-K1-15 PR-T1-3, PR-T1-15                                     |
| 4-20mA                         | RN400-T2CS |   |
| Gas                            | RN400-T2GS | RG10-NH3, RG10-H2S  |
| PM2.5<br>Particulate<br>matter | RN400-T2PM |   |

# Accessories

## Temp Sensor

| Type                                     | Model No. | Cable  |
|--|-----------|--------|
| PT100<br>-200~200°C                      | PR-P1-3   | 3 m    |
|  | PR-P1-15  | 15 m   |
| Type K Thermocouple (TC-K)<br>-50~200°C  | PR-K1-3   | 3 m    |
|  | PR-K1-15  | 15 m   |
| Type T Thermocouple (TC-T)<br>-200~200°C | PR-T1-3   | 3 m    |
|  | PR-T1-15  | 15 m   |
| NTC<br>-100~200°C                        | PR-N1-20  | 20 cm  |
|  | PR-N1-150 | 150 cm |
| Temp & RH                                | RG20      |        |

## Gas Sensor

| Type             | Model No. | Cable |
|------------------|-----------|-------|
| Ammonia          | RG10-NH3  |       |
| Hydrogen Sulfide | RG10-H2S  |       |

## Misc.

| Type                                  | Model No. | Cable |
|---------------------------------------|-----------|-------|
| Door Contact                          | AP-D1     | 1 m   |
| Alarm Beacon                          | AP-W1     | 25 cm |
| DC Adapter (EMC Core sold separately) | AP-P1     | 3 m   |

**DEKIST**  
*Embedded Web Service*

© 2021 DEKIST Co., Ltd.

Telephone 1566-4359

Fax (+82) 31-8039-4400

Email [master@dekist.com](mailto:master@dekist.com)

#A1801, 13, Heungdeok 1-ro, Giheung-gu, Yongin-si, Gyeonggi-do, Korea 16954